


Gas Information Sheet No. 26

Flue clearances



Ref.	Item	Minimum clearances (mm)	
		Natural draught	Fan assisted
a	Below eaves, balconies and other projections: <ul style="list-style-type: none"> Appliances up to 50 MJ/h input Appliances over 50 MJ/h input 	300 500	200 300
b	From the ground, above a balcony or other surface †	300	300
c	From a return wall or external corner †	500	300
d	From a gas meter (M)	1000	1000
e	From an electricity meter or fuse box (P)	500	500
f	From a drain pipe or soil pipe	150	75
g	Horizontally from any building structure † or obstruction facing a terminal	500	500
h	From any other flue terminal, cowl or combustion air intake †	500	300
j	Horizontally from an openable window, door, non-mechanical air inlet or any other opening into a building with the exception of sub-floor ventilation: <ul style="list-style-type: none"> Appliances up to 150 MJ/h input Appliances over 150 MJ/h input up to 200 MJ/h input Appliances over 200 MJ/h input up to 250 MJ/h input † Appliances over 250 MJ/h input † All fan-assisted flue appliances, in the direction of discharge 	500 1500 1500 1500	300 300 500 1500 1500
k	From a mechanical air inlet, including a spa blower	1500	1000
n	Vertically below an openable window, non-mechanical air inlet, or any other opening into a building with the exception of sub-floor ventilation: <ul style="list-style-type: none"> Space heaters up to 50 MJ/h input Other appliances up to 50 MJ/h input Appliances over 50 MJ/h input and up to 150 MJ/h input Appliances over 150 MJ/h input 	150 500 1000 1500	150 500 1000 1500

† - unless appliance is approved for closer installation

See Notes overleaf.

Gas Information Sheet No. 26

Notes:

1. All distances are measured to the nearest part of the terminal.
2. Prohibited area below electricity meter or fuse box extends to ground level.
3. Where the flue terminal of a balanced flue appliance, a fan-assisted flue appliance, a room sealed appliance or the flue terminal of an appliance designed for outdoor installation is to be installed under a covered area:
 - a) the covered area is to be open on at least two sides; and
 - b) the terminal is to be located to ensure a free flow of air across it is achieved.
4. See AS 5601 Gas Installations, for clearances required from a flue terminal to an LP Gas cylinder. A flue terminal is considered to be a source of ignition.
5. For appliances not addressed above, approval shall be obtained from Energy Safe Victoria.

If further information is required, please phone the Gas Safety Technical Information Line on 1800 652 563.

ENERGY SAFE VICTORIA